

Seattle Permits

— part of a multi-departmental City of Seattle series on getting a permit

True Seven-Day Programmable Thermostats

November 1998

The 1997 Washington State Nonresidential Energy Code requires that a true seven-day programmable thermostat be installed on mechanical systems in all commercial buildings (all occupancies other than Group R occupancy). Specifically, Section 1412.4 requires the following:

HVAC systems shall be equipped with automatic controls capable of accomplishing a reduction of energy use through control setback or equipment shutdown during periods of non-use or alternate use of the spaces served by the system. The automatic controls shall have a minimum seven-day clock and be capable of being set for seven different day types per week.

Exceptions:

1. Systems serving areas which require continuous operation at the same temperature setpoint.
2. Equipment with full load demands of 2 kW (6,826 Btu/h) or less may be controlled by readily accessible manual off-hour controls.

To fulfill these requirements, the thermostat must have a seven-day minimum clock mechanism capable of being set for seven different day types per week.

Weekday-weekend (5-2) or Weekday-Saturday-Sunday (5-1-1) thermostats do not comply with these requirements.

To assist applicants, a list of acceptable thermostats has been compiled (see reverse side). All of the thermostats are available at local retail outlets or can be ordered through local distributors. If you are unable to locate the product, call the manufacturer and they will provide the names of local sales outlets or sales representatives.

Several words of caution are in order about this list. First, the price range varies widely. Second, not all thermostats work with all space heating systems. For instance, heat pumps often require a special thermostat capable of staging the heating elements. Verify that the thermostat will work with your space heating system. Third, the products on this list are not necessarily the only acceptable products. This list will be revised as information is provided on other products.

Information to be Included on Plans

- Provide note on drawing (not in specifications alone is not acceptable) stating that thermostat has automatic controls having a minimum seven-day clock and is capable of being set for seven different day types per week per Energy Code Section 1412.4.
- Provide manufacturer and model number for thermostat when available.
- Provide one thermostat for each zone per Energy Code Section 1412.1.

www.seattle.gov/dpd



City of Seattle
Department of Planning & Development

Gregory J. Nickels, Mayor Diane Sugimura, Director

700 5th Avenue, Suite 2000
P.O. Box 34019
Seattle, WA 98124-4019
(206) 684-8600

Further Information

For projects within the Seattle city limits, if you need further information on the 1997 Energy Code requirements and compliance process, contact the DPD at 684-7846 or 684-8860 between 1:00 p.m. and 4:15 p.m., or visit the Energy Code website at www.seattle.gov/dpd/energy.

| Manufacturer | Acceptable Products |
|---|--|
| Honeywell, Inc. 9555 SE 36th St. Mercer Island, WA 98040 206-236-4042 www.honeywell.com | T7200; T7300; T7200 D,E Series 2000*; T7300 D,E,F Series 2000* PC8900*;Chronotherm IIIT8611M, T8621M; Chronotherm IVT8600D* T8601D*, T8602D*, T8611G* T8624D* (but not T8600, T8601, T8602, T8611A or T8611B). |
| White-Rodgers 9797 Reavis Road St. Louis, MO 6312 314-577-1300 www.white-rodgers.com | 1F 84-51*; 1F 87-51*; 1F 94-71; 1F 94-80; 1F 95-71; 1F 95-80; 1F 97-51, 1F 97-71; 1F 97-371* (but not 1F 80-51, 1F82-51, 1F 90-51, 1F 90-60, 1F 90-71, 1F 90-371, 1F 91-71, 1F 92W-S1, 1F 92-71.) |

* Indicates that a product is new to this list.

Access to Information

Links to electronic versions of DPD **Client Assistance Memos (CAMs)** and other helpful publications are available on our website at www.seattle.gov/dpd/publications. Paper copies of these documents are available from our Public Resource Center, located on the 20th floor of Seattle Municipal Tower at 700 Fifth Avenue in downtown Seattle, (206) 684-8467.